

HURUNUI DISTRICT COUNCIL

P.O. Box 13 | Amberley | 7441 | 66 Carters Road | Amberley | 7410
Phone 03 314-0006 | Fax 03 314-9181 | Email info@hurunui.govt.nz
Web hurunui.govt.nz | facebook.com/HurunuiDistrictCouncil
Skype [hdc_customer_services](https://www.skype.com/en/customer-services) | twitter.com/hurunuidc



Certification Plumbing

Issued by (plumber) : W Doornenbal

(To Hurunui District Council)

OWNER'S DETAILS	
Owner's name :	Daniel Pugh & Olivia Dyresen-Thin
Project address :	4 Coleman Lane Amberley
Building consent number	210544
Description of building work :	New residential dweelling


I (plumber)

have been engaged by Murchison Homes (building consent applicant)

to undertake the plumbing work on the above building consent.

I hereby certify that hot and cold water pipes have been pressure tested to 1500kPa for a period of not less than 15 minutes without pressure drop complying with NZ Building Code G12/AS1 clause 7.5.1

I understand that this certificate, if accepted, will be relied upon by Hurunui District Council for the purpose of establishing compliance with the Building Consent.

PLUMBER'S DETAILS	
Plumber's name : W Doornenbal	
Address : 80 Cullen Ave RD 5 Rangiora	
Registration number : 08518	Mobile phone : 0275135501
Phone (work) : —	E-mail address : —
Signature : 	Date : 19/9/22