



GASFITTING CERTIFICATE OF COMPLIANCE – GAS SAFETY CERTIFICATE

Certificate of Compliance:

Client Name: CP & JA Kissick
Reference / Job #: 16271
Address of work: 51 Campbell Street
Suburb: Town / City

Description of gasfitting work: (if work was done by different people, state who did what gasfitting.)

Replace existing with new hot water cylinder

Was a pre-installation gas test performed on the existing piping? Yes

Appliances

Make and Model	Serial #	Location	Input MJ/hr	Flue type	Ventilation	Qty	HR Database
Rheem 441170NO gas water heater	4825	laundry cupboard	33	Existing through roof	yes	1	No

Gas supply pressure 2.5 kPa

Risk classification Medium

Gas type Natural gas

Other (specified)

The work has been done in accordance with a certified design: No

Identify:

The work relies on manufacturer's instructions: Yes

Link: www.rheem.co.nz

The work has been done in accordance with the following means of compliance: Yes - AS/NZS 5601.1 sections 3 to 6

Were any other standards or gas code of practice required for compliance? No

If yes, then specify

This certificate relates to the All or only Part of the installation? Part

If part, then (specify)

HWC replacement

Date(s) on which the work was done:

09/03/2022

Name and registration number of anyone who carried out work under supervision:

Robin 10680 and Rico 35032

By signing this document, I confirm that I am satisfied that the work described in this certificate of compliance has been done lawfully and safely, and that the information on this certificate is correct.

Gasfitter name:

Robin

Registration number:

10680

Date:

09/03/2022

Gas Safety Certificate

By signing this document, I confirm that the work described in this Gas Safety Certificate, and the installation or part installation, is connected to a gas supply and is safe to use.

Certifier name:

Robin Houghton

Registration number:

10680

Date of completion or connection:

09/03/2022

Certifier Signature:

Date:

09/03/2022

This Gas Safety Certificate confirms that the gasfitting work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004



Master
Gasfitters
Representing Excellence

