



Certificate of Analysis

Client: MBC Environmental Solutions Limited
Client Contact: Felicity Drennan
Tel: 03 354 4377
Email: felicity@mbc.co.nz
Address: 2/97a Sawyers Arms Road, Northcote, Christchurch 8052

Focus Analytics Ltd
 8 Opawa Road
 Waltham
 Christchurch 8023
 Tel: +64 (0) 9 525 0568

Site: 19 Philpotts Road, Mairehau

Date sample(s) received: 20/12/2022

Date sample(s) analysed and issued: 21/12/2022

Samples taken by: Client

Certificate / Job Number: C-02363

Lab ID	Sample ID	Sample Details	Sample type	Sample size	Fibres Identified
1	S01	Room 1, linings	Lath & Plaster	Sufficient	ORF, NAD

Fibre Identification Key:

* – See Analytical Notes

CHR – Chrysotile (White Asbestos)
AMO – Amosite (Brown / Grey Asbestos)
CRO – Crocidolite – (Blue Asbestos)
UMF – Unknown Mineral Fibre

ORF – Organic Fibre
SMF – Synthetic Mineral Fibre
NFD – No Fibres Detected
NAD – No Asbestos Detected

Sample Size Guide:

- **Sufficient** – Sample weight >1g
- **Limited** – Sample weight between 0.5 -1g
- **Insufficient** – Sample weight <0.5g, small size could misrepresent what is in sampled material. Suggest client obtains a larger sample.

Analysis Methods:

1. Samples submitted have been analysed to determine the presence of asbestos using low powered stereo microscopy followed by polarised light microscopy including dispersion staining techniques as documented in AS 4964-2004 and in company procedures NPM-TP03 Technical Procedure for Qualitative identification of asbestos in bulk samples.
2. Any opinions and interpretation of test results fall outside the scope of accreditation.
3. Focus Analytics did not carry out any sampling and the data presented are based on the samples submitted.
4. This certificate should be read in its entirety and shall not be reproduced except in full, without written approval of the laboratory.

Analyst Name: Brigitt White

Analyst Signature:

Reviewed By KTP: Brigitt White

Reviewer Signature: