

New Brighton
 CHRISTCHURCH 8641

Re: Asbestos Identification Analysis - 19 Philpotts Road, Mairehau

At the request of PB Goosey Ltd, a sample of suspected asbestos material was collected from 19 Philpotts Road, Mairehau by Chemsafety on 19 May 2016 for asbestos identification analysis.

Analysis Results

Samples are analysed for asbestos in accordance with AS4964-2004 (Method for the qualitative identification of asbestos in bulk samples) using Low Powered Stereomicroscopy followed by 'Polarised Light Microscopy' including dispersion staining techniques.

Samples were collected only at locations as specified by the client, and this report does not constitute an audit of the property. Results are presented in Table 1.

Asbestos containing materials may be present in other areas of the property not included in this testing. Ensure any suspected asbestos containing materials have been tested prior to disturbance.

Table 1 - Asbestos Analysis Results

Analysis by Dowdell & Associates Ltd, reference: 16-022084.

Sample	19 Philpotts Road, Mairehau	Result
69134	Master Bedroom Ceiling <i>Stipple over Lath & Plaster</i>	Asbestos was not detected in the sample



David Alexander

Client References:

All work is undertaken subject to Chemsafety's General Terms and Conditions of Trade, a copy of which can be found at www.chemsafety.co.nz/chemical-consultancy-resources.html.

© Chemsafety Ltd 2016 (unless otherwise agreed in writing with the Client)

This report has been prepared by Chemsafety Ltd on the specific instructions of our Client. It is solely for our Client's use for the purpose for which it is intended with the agreed scope of work. Any use or reliance by any person contrary to the above, to which Chemsafety has not given its prior, written consent, is at that person's own risk.

Electronic (pdf) reports may be provided. Should (on rare occasion) an amended report be issued, Chemsafety Ltd can have no control over already issued electronic documents. Please refer to the final hard copy report, or contact Chemsafety to verify whether revised versions exist.