



Compliance and Electrical Safety Certificate

Unique ID: 3696.1/E244224

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

(1) Location of Installation or Part Installation

Address: 19 Belfield Street, Christchurch, 8061

(2) Customer / Occupier / Owner Information

Name: Trademate Ltd T/A Hot Water Shop

Address: 19 Belfield Street, Christchurch, 8061

Email: accounts@hotwatershop.co.nz

Phone:

(3) Electrical Worker Information

Name: Simon Wheeler Registration/Practising Licence No: E244224

Organisation: Wheeler Electrical Ltd

Phone: +64212782213

Email: simon@wheelerelectrical.co.nz

Name of person(s) being supervised: Lance Anderson, Patrick Mcpherson(ETLC139496)

(4) Work Details

This work is: ☒ Is New Work ☐ Is Addition ☐ Is Alteration ☐ Is Maintenance

The prescribed electrical work is: ☐ High Risk ☒ General ☐ Low Risk ☐ Home Owner

Reference Standards: ☐ Part 1 of AS/NZS 3000 ☒ Part 2 of AS/NZS 3000 ☐ AS/NZS 3012

☐ Addition Standards:

Indicate the number of each item installed or altered:

Lighting Outlets: Socket Outlets: 1 Ranges: Water Heaters:

Indicate if work includes:

☐ Mains ☒ MEN SWBD closest to Point of Supply ☐ Earthing System ☐ Electrical Lines

Work Done: wired in gas on socket on existing rcd at board took power off kitchen socket disconnected solar controller (might be getting moved onto sleepout)

Liven and test >> ALL OK

The work was done within the period: Date Commenced: 22/06/2021 Date Completed: 22/06/2021

(5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- | | |
|---|---------------------------------------|
| <input type="checkbox"/> Relies on manufacturer's instructions | <input type="checkbox"/> Attached/Ref |
| <input type="checkbox"/> Relies on Declaration of Conformity | <input type="checkbox"/> Attached/Ref |
| <input type="checkbox"/> Accordance with certified design | <input type="checkbox"/> Attached/Ref |
| <input checked="" type="checkbox"/> Tested in accordance with ESR2010 | |
| <input checked="" type="checkbox"/> Earthing system that is correctly rated | |
| <input checked="" type="checkbox"/> Fittings safe to connect | |
| <input checked="" type="checkbox"/> Safe to connect to a power supply | |

Test Results	
Continuity of Earthing System:	.1
Insulation Resistance:	999
Polarity – Correct Circuit Connections:	yes
Verification of Impedance:	
Operation of RCD's:	yes

Signature:

Date: 10/07/2021

(6) Electrical Safety Certificate

(to be completed by the person who connects the installation, or part installation to the power supply)

I certify that the installation, or part of the installation as described above, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use. If maintenance, alteration or addition, has not adversely affected any other part of the installation.

Name: _____ Registration/Practising Licence No: _____

Signature: _____ Issue Date: _____ Connection Date: _____