



GASFITTING CERTIFICATE OF COMPLIANCE
– GAS SAFETY CERTIFICATE
(GREG LILBURNE 027 315 0664)



Client Name: Hotwatershop Ltd

Reference / Job #: G2375 **ICP (if known):**

Address of work: 19 Belfield st

Suburb: Dallington **Town / City:** Christchurch 8061

Description of gasfitting work: (If different gasfitting work was done by different people, state who did what gasfitting.)

Install external gas califont and bottle station on south wall, pipework under floor.
Tested system at 3.5 kPa for 7 mins – nil leak.

Rheem waterheater Model 874826 LFZ s/n H13-0121901785 194 MJ/hr

Gas supply pressure 3.0 kPa **Risk classification** (tick one) ☐ Low-Risk ☒ General ☐ High-risk

Gas type (tick one) ☐ Natural gas ☒ LPG ☐ Biogas ☐ Other (specify)

The work relies on manufacturer's instructions: ☐ No ☒ Yes:

If yes – identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link: rheem.co.nz

The work has been done in accordance with means of compliance (specify):

☒ Yes – AS/NZS 5601.1 sections 3 to 6 ☐ Yes – AS/NZS 5601.2 sections 3 to 9 ☐ No

Were any other standards or gas code of practice required for compliance?

☒ Yes (specify) NZBC Clause E2, G10, G11 ☐ No

Parts of the gas installation to which this certificate relates that are safe to connect to a gas supply?

☒ All ☐ Parts (specify)

Date(s) on which the work was done: 22 / 6 / 2021

Name and registration number of anyone who carried out work under supervision:

By signing this document I confirm that I am satisfied that the work described in this certificate of compliance has been done lawfully and safely, and that the information on this certificate is correct.

Certifier name: G Lilburne

Registration number: 18302

Certifier Signature:

Date: 29 / 6 / 2021

Gas Safety Certificate:

By signing this document I confirm that the work described in this Gas Safety Certificate, and the installation or part installation, is connected to a gas supply and is safe to use.

Name of person authorised to certify the connection: G Lilburne

Registration number: 18302

Date of completion or connection 22 / 6 / 2021

Certifier Signature:

Date: 29 / 6 / 2021