



ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID NO.: 7755320

This Electrical Safety Certificate provides a legally recognisable statement that the connected installation or part installation, or any fitting that supplies an installation or a part of an installation, is safe to use following prescribed electrical work.

Location Details: 43 Tovey Street, New Brighton, Christchurch

Contact Details: Wilma Van Hellemond
(Name and address)

Details of work: The whole installation Part of the installation

Description of work: Removed and replaced a damaged cable between main dwelling and secondary dwelling with new 2.5mm TPS.

Replaced existing mechanical protection with UV rated flexible conduit supported by a catenary wire as the old mechanical protection was not fit for purpose.

Tested at time of re-connection.

Date of connection:

11/12/2025

By signing this document I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Joshua Cosgrove

Registration/Practising licence number:

E004369

Certifier's signature:

Certificate Issue Date:

12/12/2025

Email:

josh.lightsideelectrical@gmail.com

Organisation/ Company:

LightSide Electrical

**CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND
SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS**

This electrical safety certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.



Electrical Certificate of Compliance

EWRB 551

for prescribed electrical work that is carried out on electrical installations and involves the placing or positioning or the replacing or repositioning of conductors (including fittings attached to those conductors).

No.

1066694

No. of attachments

CUSTOMER INFORMATION - PLEASE PRINT CLEARLY

Name of customer

Ms Wilma Van Hellemond.

Telephone

Fax

Address of installation

43 Tovey St chel.

Postal address of customer (if not as above)

WORK DETAILS

No. of lighting outlets

No. of ranges

No. of socket outlets

No. of water heaters

Was any installation work carried out by the homeowner?

 Yes No

Please tick (✓) as appropriate where work includes:

Mains

Main earth

Switchboard

Electric lines

Description

Install 16mm mains & 6mm
dwng earth. New Sw. Board
outdoor meterbox

Use sketch if necessary

CERTIFICATION OF WORK

I certify that the above electrical work has been carried out in accordance with the requirements of the Electricity Act 1992 and Electricity Regulations 1997

ELECTRICAL WORKER DETAILS

Name

Graham Smith

Registration no.

E4252

Company

G. S. Connections

Signature

Date

13-3-01

CERTIFICATION OF ELECTRIC LINES

(to be completed where "Description of Work" includes "Electric Lines")

Name

Registration no.

Company

Signature

Date

INSPECTION DETAILS

 Electrical work requiring inspection by a registered electrical inspector New mains Switchboard Earthing system Installation work in hazardous areas

I certify that the inspection has been carried out in accordance with the requirements of the Electricity Regulations 1997.

Name

D.J. Tobin

Registration no.

T 927

Signature

Date

13.3.01

Statement of Compliance Domestic Electrical Work

No. D

661703

prescribed electrical work that is carried out on electrical installations and that involves the placing or positioning or the replacing or repositioning of conductors (including fittings attached to those conductors).

No. of attachments

CUSTOMER INFORMATION - PLEASE PRINT CLEARLY

Name of Customer Ms W Van HellenoudTelephone Fax Address of Installation 43 TOVEY ST CH CHPostal Address of Customer (if not as above)

WORK DETAILS

7 No. of lighting outlets No. of ranges

9 No. of socket outlets No. of water heaters

Was any installation work carried out by a homeowner? Yes No

Please tick (✓) as appropriate where work includes:

 Mains Main earth Switchboard Electric linesDescription Rewire 7 lights & 9 P/Point.

Use sketch if necessary

CERTIFICATION OF WORK

I certify that the above electrical work has been carried out in accordance with the requirements of the Electricity Act 1992 and Electricity Regulations 1997.

ELECTRICAL WORKER DETAILS

Name G. SmithRegistration No. E 4252Company A.S. ConnectionsSignature Date 5/4/01

CERTIFICATION OF ELECTRIC LINES

(to be completed where "Description of Work" includes "Electric Lines")

Name Registration No. Company Signature Date

INSPECTION DETAILS

Electrical work requiring inspection by a registered electrical inspector

 New mains Switchboard Earthing system Installation work in hazardous areas

I certify that the inspection has been carried out in accordance with the requirements of the Electricity Regulations 1997.

Name Registration No. Signature Date

MATERIALS	QTY. SUPPLIED	Unit Price	Trade	Trade Price Excluding GST
16mm Twin TPS	7	15		105
Crimps	6	0.8		4.8
Junction Boxes	10	7.48		74.8
Strip connectors	2	6.22		12.44
Heat shrink	4	4.5		18
Inspection Fee	1	40.89		40.89
Meter Box	1	85		85
Switch Board	1	75		75
Main Switch	1	14		14
MCB	7	12		84
Earth Tag	1	1.5		1.5
Earth Wire	9	6		54
				0
				0
Earth Stake	1	16		16
Main Entry Box	1	85.38		85.38
Earth Wire	1.5	6		9
Earth Clamp	1	6.5		6.5
Conduit/Casing	0.5	15		7.5
16mm Twin TPS	4	15		60
				0
2.5mm TPS T&E	16	4.05		64.8
Lamp Holder	1	6.94		6.94
Insulation Tape	1	2		2
Double Switch Socket	1	23.22		23.22
Plate 4 gang	1	6.17		6.17
Sensor Mech.	1	12.41		12.41
Switch mech.	3	7.61		22.83
				0
08/03/01	8.5	20		170
13/03/01	11	20		220
21/03/01	5	20		100
04/04/01	1	20		20
				1402.18
				0
				0
			GST =	155.8
			Total + GST =	1557.98

New Mains and Earth.
Rewire kitchen, bedrooms
, lounge, and front room
lights and power points.
Install outside light.

GST REG. No 44-386-389

TAX INVOICE 1342

Phone :388 5803
Mobile:025 324 223
Fax:388 1318

ENSLOW ELECTRICS

Quality Electrical Service

184C ROCKINGHORSE RD
SOUTH SHORE
CHRISTCHURCH 7.

WILMA van HELLEMOND

ORDER No. :
Invoice Date: 6/12/00
PAGE 1 OF 1

Materials	Quantity	Price	Extension
ELECTRICLA SAFETY CHECK AND REPORT FOR 43 TOVEY ST. CHRISTCHURCH.			
WIRECHECK, TEST AND REPORT.	1.00	66.67	66.67

Pd Cheq 100/182
10.12.00

Sub Total	\$66.67
Labour	
Call Out Fee	
Mileage	
GST	\$8.33
INVOICE TOTAL	\$75.00

Title of goods shall not pass until full payment is received



Compliance and Electrical Safety Certificate

This form has been issued by the Electrical Workers Registration Board



Safety • Competency

This form has been designed to be used by licensed electrical workers to certify low voltage installations or part installations that comply with Part 2 of AS/NZS 3000 and are safe to be connected to a 230/400 volt multiple earth neutral (MEN) system of electrical supply.

(1) Location of installation

Address: 43 TOWN ST, NEW BREMEN

(2) Customer Information

Name: Barry Hall

Postal Address: Barry Hall Services

Phone and Email:

(3) Electrical Worker Information

Name: Barry Hall Registration/Practising Licence Number: E246233

Organisation: OCMANS Electrical Telephone Number: 0210708159

Email:

Name of person(s) being supervised:

(4) Work Details

The work is (circle): additions | alterations | new work

The prescribed electrical work is: High Risk General Low Risk The homeowner has undertaken part of the electrical installation work.
(Please tick (✓) as appropriate)

Indicate the number of each item installed or altered:

Number of lighting outlets: 10

Other Work?

REINSTATE

Tick (✓) if work includes:

Number of socket outlets: 10

REINSTATE

Mains

Number of ranges: 1

REINSTATE

MEN switchboard closest to point of supply

Number of water heaters: 1

REINSTATE

Main Earthing System

Electric Lines

(5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- has been installed in accordance with a certified design
- has an earthing system that is correctly rated
- contains fittings which are safe to connect to a power supply
- relies on supplier's Declaration of Conformity (attach or reference¹)
- relies on manufacturer's instructions (attach or reference¹)
- has been satisfactorily tested in accordance with Electricity (Safety) Regulations 2010
- is safe to connect

Test Results:		
	Electrical Worker	Inspector
Polarity (independent earth):		
Insulation resistance:		
Earth continuity:		
Bonding:		
Other (specify):		

Electronic reference:

Electrical Worker's Signature: Barry Hall Date:

1. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declarations of conformity, provide a reference to where the documents can be found, in a readily accessible format, through electronic means.

(6) Electrical Safety Certificate

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use

Name: Barry Hall Registration/Practising Licence Number: E246233

Signature: B Hall (if certifier is different from electrical worker) Date 13/12/13

4 Seasons Christchurch Limited

Tower Junction Mega Centre
 Blenheim Road
 Christchurch
 Ph 03 341 1220 FAX 03 341 1221

QUOTATION

No.: 25606

Date: 05/11/13
 GST No.: 97-557-047
 Customer: VANHELLE
 Order Number:
 Our Reference:

Charge TO:
 Wilma Van Hellemond
 43 Toveys St
 South Brighton
 , CHRISTCHURCH
 Phone: 3883008

Fax:

Delivery: Wilma Van Hellemond
 43 Toveys St
 South Brighton
 , CHRISTCHURCH PH: 3883008

Contact: SIMON BROWN

Code	Description	Units	Quantity	Price	Disc%	Amount
HFT-3041	WOODSMAN ECR MK III WOODBURNER	EACH	1.00	1599.00		1599.00
HFT-7127..	WOODSMAN HEATSAYER 4.2M INCL 900MM SHIELD - ECR ONLY	EACH	1.00	799.00		799.00

THIS QUOTE IS VALID FOR 30 DAYS FROM DATE SHOWN. SUBJECT TO MANUFACTURES PRICE INCREASES. QUOTE INCLUDES GST. No discount given on gift vouchers or hot points

Client: VANHELLE Wilma Van Hellemond

QUOTATION No.: 25606

TOTAL 2398.00

2427.55

5.55

Check
All
8/11/2013

Heating Installations Carty Ltd
P O Box 7729
CHRISTCHURCH 8240

ph 339 4444

QUOTATION

Wilma Van Hellemond
43 Tovey Street
New Brighton
Christchurch 8061

Quotation No.: 00501652
Date: 8/11/2013

GST Reg. Number: 83-091-592

Dear Wilma

Thank you for the opportunity to quote for the installation of a Woodsman ECR MK11 Logfire at your property 43 Tovey Street, New Brighton. The price is as follows.

Woodsman ECR MK11 Logfire With 150mm Flue Kit & Shield - 4 Seasons -

1 x 600 150mm SS		\$49.00
1 x 600 250mm Galv Liner		\$39.00
Dektite Soaker		\$150.00
Wall Hearth		\$390.00
Bracing Rods		\$110.00
Misc Materials		\$65.00
Building Consent		\$273.91
Processing Fee		\$95.00
1 x Smoke Alarm		\$19.00
2 x Heat Wall (Steel)	If Required	\$240.00
Installation Charge		\$680.00

NB: Builder to remove fire place to floor level & build alcove to spec. Include heatwalls

Yours faithfully	Sub total:	\$2,110.91
	GST:	\$316.64
	Total Amount:	\$2,427.55

Andrea Newburgh
Heating Installations Carty. Ltd

Acct number to pay online: 06 0829 0116590 00

IMPORTANT: Should you wish to accept this quote, please do the following:

Order the fire from the retailer concerned.

NB: Hearths quoted will be black with timber trim unless otherwise specified by the home owner at acceptance.

50% deposit on acceptance of quote, & balance due on completion of the installation. Please note, we do not accept any credit cards.

No plumbing has been allowed for unless specified; any plumbing required will be at additional costs.

FOR INSERT FIRES: Where the chimney cannot be viewed prior to installation, flexi flue may be required; this will be at additional costs.

Quoted price is valid for 30 days from above date.
See reverse for Terms and Conditions.

email: admin@hicl.co.nz