

# Combined Certificate of Compliance & Electrical Safety Certificate



**75**

Customer Name: Julie Hartnell

Location of Installation: 75 Fourth Ave  
Whangarei

CE 123434

Description of work: (or see attached)

Install new extractor fan in bathroom  
Replace 3x switches in oven



Reference / Job / ID

This work has been carried out in accordance with a Certified Design  Certified Design Attached

ICP Number (if known)

Name of Issuer of Certified Design: \_\_\_\_\_

Supplier Declaration of Conformity Attached:  (please attach or list Certificate serial numbers or web address below)

Manufacturers Instructions used or relied on in this work:  (please attach or list web address below)

All parts of the installation are safe to connect to a power supply  
If not, please detail which parts are safe to connect.

**This work is:**

Low Risk   
(Certificate of Compliance not required)

General

High Risk   
(Record of Inspection required)

**This work has been done in accordance with:**

Part 2 of AS/NZS 3000

Part 1 of AS/NZS 3000

**Supply system this work is suitable for:**

230/400V MEN system

Other (Please specify)

Other Standards this work complies with: \_\_\_\_\_

**Record of Inspection (If Required)**

The aspects of the work which make it high risk are:

- Work on Mains
- Work on Main Earthing System
- Electromedical
- Hazardous Area
- Mains Parallel Generation
- Mines
- Photovoltaic
- Animal Stunning
- Work to Part 1 of AS/NZS 3000 \*
- High Voltage \*

\* Certified Design Required

Date on, or period in, which the work was done: 23/8/18

I confirm that I am satisfied that the work detailed in this Certificate of Compliance has been done lawfully and safely, and that the information contained in this certificate is correct and accurate.

This certificate is issued by: Mark Sim  
Signature: MS

Registration No: E200449  
Date: 23/8/18

Name and Registration Numbers of Workers Under Supervision Attached

**Electrical Safety Certificate** To be completed once all work on the CoC above is completed.

Date the connection was done: 23/8/18

I am satisfied that the work detailed in this Electrical Safety Certificate and the installation or part installation to which it relates is connected to a power supply and is safe to use.

The work described above was connected by: Mark Sim  
Signature: MS

Registration No: E200449  
Date: 23/8/18

75

**ONE ELECTRICAL SERVICES**

22 Harbour View Road  
Onerahi  
Whangarei 0110

Office: 022 474 4945  
Mob: 027 431 4945

**TAX INVOICE**

GST No. 61-130-640

**Date**

18-Jun-16

**Invoice #**

1379

**Due Date**

20-Jul-16

**ACCOUNT TO**

Personalised Property Management  
243 Rosythe Road  
Waipu 0582  
Ph: 0226453895 or 09 4321009  
ppmnzl@gmail.com

Description	Quantity	Unit Price	Amount
-------------	----------	------------	--------

27.05.16 - Checked Wiring of Bungalow at 75 Fourth Avenue, Whangarei  
Tenant: Anna 021 192 1129 or Hayden 021 190 6274

Labour	1	55	55.00
--------	---	----	-------

**NB:** Visual check of house wiring condition.

The Switchboard has been upgraded at some stage with MCB's and RCD (residual current device) protection on the power point and light circuits.

Did not see any of the older black insulated cable still in use. All cables into the switchboard was of TPS type with varying ages. All looked to be of sound condition.

Some switches and power points have been changed to a modern type but alot of the house has the older type which goes with the style of home and are in working order.

*pd 20.06.16 930051*

**Terms of trade:**

All accounts are payable by the 20th day of the month following the date of the invoice. If the account is not paid within 30 days after the due date, you will be charged interest at the rate of 2% per month, and you may also be liable for all debt collection fees on unpaid accounts.

**Direct Credit to:**

ANZ Bank  
One Electrical Services  
01 0487 0188489 00

OR

Cheques payable to:  
One Electrical Services

Amount Less GST	55.00
-----------------	-------

Total GST	8.25
-----------	------

<b>TOTAL</b>	<b>63.25</b>
--------------	--------------

75

# Electrical Safety Certificate



Customer Name: Julie Hartnell  
Location of Installation: 75 Fourth Ave  
Margaret

CE 123434

Description of work: (or see attached)  
Install new extractor fan in bathroom.  
Replace 3X switches in oven.



This work has been carried out in accordance with a Certified Design  Certified Design Attached  (CP Number (if known))

Supplier Declaration of Conformity Attached  (please attach or list Certificate serial numbers or web address below)  
Manufacturers Instructions used or relied on in this work  (please attach or list web address below)

Work completed in accordance with AS/NZS 3000:2007

This work is:  
Low Risk   
Medium Risk   
High Risk

This work has been done in accordance with:  
Part 1 of AS/NZS 3000   
Part 2 of AS/NZS 3000

Supply system this work is suitable for:  
Domestic AC Supply   
Other (Please specify)

Other Standards this work complies with:

Record of Inspection (if Required)  
The aspects of the work which make it high risk are:  
 Work on Mains  Main Parallel Generation  Annual Straining  
 Work on Main Earthing System  Mains  Work to Part 1 of AS/NZS 3000\*  
 Electromedical  Photovoltaic  High Voltage\*  
 Hazardous Areas \* Certified Design Required

Date on, and period in, which the work was done: 23/8/18

I confirm that I am satisfied that the work detailed in this Certificate of Compliance has been done lawfully and safely, and that the information contained in this certificate is correct and accurate.

This certificate is issued by: Nick Sim  
Signature: NBS

Registration No: E261471  
Date: 23/8/18

Name and Registration Numbers of Workers Under Supervision Attached

## Electrical Safety Certificate

Date the connection was done: 23/8/18

I am satisfied that the work detailed in this Electrical Safety Certificate and the installation or part installation to which it relates is connected to a power supply and is safe to use.

The work described above was connected by: Nick Sim  
Signature: NBS

Registration No: E261471  
Date: 23/8/18