



# New Zealand Gas Safety Certificate & Gas Certificate of Compliance

**Customer Name**

Proper Job Properties Ltd

**Job Number**

NVGH-1144

**Certificate ID**

NVGH-1144C1

**Site address**

33 Nancy Avenue, Mairehau, Christchurch, 8052

**Gas Certificate is for**

Parts

**IF PARTS - Please specify**

Gas hob Installation

**Risk classification**

General

**Description of gas work carried out****1** **Installer Name** Nimo Vili**Licence Number** 26863**Date** 24/10/2025**Description of work undertaken**

Onsite , Disconnect existing cooker , De-commission gas supply line to gas cooker and cap off at bottlestaion . Prepipe new hob postion ,back to back ready to connect at fitoff..

**2** **Installer Name** Nimo Vili**Licence Number** 26863**Date** 12/01/2026**Description of work undertaken**Onsite ,fitoff gas hob & convert LPG . Connect gas linr to existing gas supply, TEst line test sound.  
Commission gas hob & set presuures , check for leaks & visual ,all clear.  
Test Sound.**3** **Installer Name** \_\_\_\_\_**Licence Number** \_\_\_\_\_**Date** \_\_\_\_\_**Description of work undertaken****4** **Installer Name** \_\_\_\_\_**Licence Number** \_\_\_\_\_**Date** \_\_\_\_\_**Description of work undertaken**



# New Zealand Gas Safety Certificate & Gas Certificate of Compliance

## Description of gas appliances

#### Parts of the gas installation that are safe to connect to a gas supply

**Connection Date**

## Gas Supply Pressure

All

12/1/2026

2.80 kPa

**IF PARTS - Please specify**

### Gas Type

LPG

**IF OTHER - Please specify**



# New Zealand Gas Safety Certificate & Gas Certificate of Compliance

## Test Results

Duration	8 mins
Test Pressure	2.81 kPa
Loss/Gain	0.01 kPa
Gas Supply Pressure	2.80 kPa

## Test Date

12/1/2026

## Other testing

Combustion

Yes

Ventilation

Yes

## Additional Information

The work has been done in accordance with means of compliance (specify)

Yes - AS/NZS 5601.1 section 3 to 6

Were there any other standards or gas code of practice required for compliance?

No

IF YES - Please specify

## Attachments

The work relies on manufacturers instructions

Yes

The work has been done in accordance with certified design

No

Where practical the manufacturer instructions or designs must be attached at the end of this certificate. If not, please provide a reference here for where these can be found.

## Reference

## Gas Certificate of Compliance

By signing this document I confirm that I am satisfied that the work described in this certificate of compliance has been done lawfully and safely and that the information on this certificate is correct.

Certifier Name

Nimo Vili

Licence Number

26863

Certificate Issue Date

13/01/2026

Signature

## Gas Safety Certificate

By signing this document I confirm that the work described in this certificate complies with the building code for the purpose of Section 19(1)(e) of the Building Act 2004.

By signing this document I confirm that the work described in this certificate and the installation or part installation is connected to a gas supply and is safe to use.

## Gas Connection Details

Only enter and sign the installer details if the person who completed the gas connection is someone other than the certifier.

Certifier Name

Nimo Vili

Licence Number

26863

Certificate Issue Date

13/01/2026

Signature

Gasfitter name

Licence Number

Signature