

New Zealand Gas Safety Certificate & Gas Certificate of Compliance



Customer Name

Brendon Harris

Job Number

HQ-1551

Certificate ID

HQ-1551C1

Site Address

Street Address 241 Lake Terrace Road

Suburb Shirley
City, Postcode Christchurch, 8061

Risk classification:

Low-risk General High-risk

Gas Certificate is for

Whole installation Parts

Description of gas fitting work carried out

Installer Name	Licence Number	Date	Description of work undertaken
James Redmond	22142	27/10/2020	Installed a rheem 26 gas unit , full bottle station , 20mm rifeng pipework from the unit to the gas station , carried out a gas test , no drop , tested , set working pressure at 2.75kpa.

Parts of the gas installation that are safe to connect to a gas supply

All Parts

Connection Date

27/10/2020

Gas Supply

Pressure

2.75 kPa

Gas Type

Natural Gas LPG Bio Gas
 Other

Test Results

Duration	7	mins
Test Pressure	3	kPa
Loss/Gain	0	kPa
Gas Supply Pressure	2.75	kPa

Test Date

27/10/2020

Other Testing

Combustion Yes No

Ventilation Yes No

Additional Information:

The work has been done in accordance with means of compliance (specify)

- Yes - AS/NZS 5601.1 section 3 to 6
 Yes - AS/NZS 5601.2 section 3 to 9
 No

Were there any other standards or gas code of practice required for compliance?

Yes No

Attachments

The work relies on manufacturers instructions
The work has been done in accordance with certified design

Yes No
 Yes No

Where practical the manufacturer instructions or designs must be attached at the end of this certificate. If not, please provide a reference here for where these can be found.

Reference

Gas Certificate of Compliance

By signing this document I confirm that I am satisfied that the work described in this certificate of compliance has been done lawfully and safely and that the information on this certificate is correct.

Certifier Name **James Redmond**

Licence Number **22142**

Certificate Issue Date **27/10/2020**

Signature 

Gas Safety Certificate

By signing this document I confirm that the work described in this certificate complies with the building code for the purpose of Section 19(1)(e) of the Building Act 2004.

By signing this document I confirm that the work described in this certificate and the installation or part installation is connected to a gas supply and is safe to use.

Certifier Name **James Redmond**

Licence Number **22142**

Certificate Issue Date **27/10/2020**

Signature 