

CERTIFICATE OF ANALYSIS

Asbestos Identification

Certificate No: 26-3821

Client:	SQN Consulting	Date Sampled:	22/04/2026
Client Contact:	Merril	Date Received:	23/04/2026
Telephone:	021 881 785	Date Analysed:	23/04/2026
Email:	results@sqn.co.nz	Date Issued:	23/04/2026
Address:	220J Bush Road, Rosedale, Auckland 0632	Order No.:	L-10506
Site:	3 Magnolia Avenue, Te Kamo, Whangarei - L-10506 - 22.4.26	Sampled By:	As Received

Test Method:

Qualitative identification of asbestos types in bulk samples at PROLABS Laboratory by polarised light microscopy, including dispersion staining techniques using PROLABS in-house method ID-1, AS4964 (2004).

Lab ID	Sample ID	Sample Details	Sample Type	Size / Weight cm/g	Fibres Identified	Asbestos Present
001	S001	Textured ceiling - hall, kitchen, laundry	Textured Coating	3 x 3	NAD, ORF	No


Fibre Identification Legend

CHR	Chrysotile (white asbestos)	ORF	Organic Fibre
AMO	Amosite (Brown/Grey asbestos)	SMF	Synthetic Mineral Fibre
CRO	Crocidolite (Blue asbestos)	NAD	No Asbestos Detected
UMF	Unknown Mineral Fibre	hpd	Handpicked

All samples submitted by clients for laboratory testing are retained by the laboratory for a period of 3 months.

Approved Identifier

Name: Joy Chen



Approved Signatory

Name: Philip Torley



PROLABS accepts no responsibility for the initial collection, packaging or transportation of samples submitted by external persons. Analysis of dust samples collected using adhesive tape or swabs/wipes is not covered under AS 4964 and our IANZ Accreditation. This document may not be reproduced except in full.