

Important Note: The following inspection checklist must be read in conjunction with the Auckland Council Inspection Code of Practice where individual line items have been defined to support reasons for decisions. N/A means Not Applicable (not part of this inspection)

* Indicates a photo has been taken in relation to a particular line item

Inspection Details	
Inspection Type Code	Swimming pool fencing(SWP)
Date of inspection	07-05-2019
Start time	12:16:21
Does the checklist need to be completed?	Yes

Checklist Item	Result	Comment
Choose method of determining compliance	FOSPA	
FOSPA- type of pool as per Council records	Pass	
Type of pool	Above ground spa, In ground	
Pool fencing area as per previous inspection/ plans and defines the immediate pool area	Pass	
Immediate pool area free from non-pool associated activities	Pass	
Pool fencing minimum 1.2m height above and away from (in an arc) ground level or any permanent projections	Pass	
Fencing horizontal rails and climbable features are at least 900mm apart (i.e barrier has 900mm no climb zone)	Pass	
Gaps under or through the fence < 100mm dia sphere	Pass	
Steel wire mesh max openings 13mm. If openings 13-35mm height to be 1.8m. No openings greater than 35mm	N/A	
Boundary fence min height and no climb zone	N/A	
Balcony / deck > 2.4m above pool area- barrier 1m min height. < 2.4m- barrier 1.2m min height.	N/A	
Returns/solid barriers installed to prevent climb arounds	N/A	
Gate swings away from pool, self closes and self latches from 150mm open	Pass	
Gate swings clear of anything that may prevent the gate from closing	Pass	
Latch 1.5m above ground/permanent projection.Or only accessible by reaching at least 1.2m and over or through the gate	Pass	
Doors self latch and self-close with latch at 1500mm height?	N/A	
Doors self latches and fitted with an audible warning device	N/A	
Doors fitted with a top bolt or latch at 1500m if approved before 2017	Pass	
"SWIMMING POOL - CLOSE DOOR" sticker displayed between 1200mm and 1500mm	Pass	
Window less than 2.4m above pool area	Pass	
Fencing subject to FOSPA section 5e "exemption" or F9 modification	N/A	

LBP Name (if applicable)	LBP Number	LBP Class
Not applicable to this inspection.		

Documents required	Comment
Not applicable to this inspection.	

Minor Variation Description (if applicable)	Outcome	Outcome reason / Comment
Not applicable to this inspection.		

Inspection Summary	
Fail Comments	Not applicable to this inspection.
Inspector's additional comment	Your pool fencing inspection has passed and your next inspection will be in approx 3 years time. Please remember to maintain your fencing and gates to keep your pool safe. If you have any further queries regarding this inspection, please call (09) 353 9143. Alternatively, you can go online at; https://www.aucklandcouncil.govt.nz and search ""pools"" Please note, the fee for this inspection is \$128. An invoice will be sent separately. Thank you
Inspection Outcome	Pass
Person on site (name)	N/A
Inspection outcome statement recipient email	office@safetsleep.com
Inspector's name	Michael Viliua
Inspector's email	MICHAEL.VILIUA@AUCKLANDCOUNCIL.GOV.T.NZ
Inspectors phone number	+64 27 270 6958
Inspection duration (minutes) Note- Time may be added for travel and additional processing (eg minor variations)	20

Photos	
SWP20454342 SWP Inspection 07/05/2019	

SWP20454342 SWP Inspection 07/05/2019



SWP20454342 SWP Inspection 07/05/2019

