



Electrical Workers Registration Board

SAFETY | COMPETENCY | COMPLIANCE

Electrical Certificate of Compliance and Electrical Safety Certificate

Reference/Certificate ID No: 0053



This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under **Part 1 or Part 2 of AS/NZS 3000** are safe to be connected to the **specified** system of electrical supply.

LOCATION AND CONTACT

Location Details	417 Te Moana Rd Waikanea	Contact Address	
Contact Name	Micheal Meads	Postcode	
Name of Electrical worker:	Bryan Smith	Registration/Practising licence number:	E19972
Organisation/ company:	Smith Electrical		
Phone:	0212531650	Email:	smithelectrical@outlook.com
Name of person(s) supervised:			

CoC

Type of work:	☐ Additions	☐ Alterations	☒ New work
The prescribed electrical work is:	☐ Low risk	☐ General	☒ High risk (specify):
Reference Standards:	☐ Part 1 of AS/NZS 3000	☒ Part 2 of AS/NZS 3000	
	☐ Additional Standards:		

Description of work: (including date/s of work and type of supply system)

Install new spa power supply and external power point for existing gas water heater. Spa supply is 2.5 T/
E 20A MCB off 40A RCD to new isolator. HP from existing MCB off new 40A RCD. RCD Test 29mS max trip point.

I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct in that the installation, or part of the installation:

Select those that apply:

- ☒ Has been installed in accordance with the specified certified design¹
- ☒ Has an earthing system that is correctly rated (where applicable)
- ☒ Contains fittings that are safe to connect to a power supply
- ☒ Relies on a supplier Declaration of Conformity¹
- ☒ Has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010
- ☒ Is safe to connect

Electronic/Other reference:

Certifier's signature:

Test Results	
Polarity (independent earth):	Correct
Insulation resistance:	100 Mohms
Earth Continuity:	0.1
Bonding:	0.1
Fault Loop Impedance:	0.98
Other (specify):	

Date: 17 / 07 / 18

¹ Attach or reference. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declaration of conformity, provide a reference to where the documents can be found, in a readily accessible format, by electronic means.

ESC

I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:	Bryan Smith	Registration/Practising licence number:	E19972
Certifier's signature:		Certificate Issue Date:	17 / 07 / 2018
		Connection Date:	17 / 07 / 2018

CUSTOMER COPY - THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.

UPGRADE OF ELECTRIC METRE.



BRIEN ELECTRICAL



ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

BRIEN ELECTRICAL JOB #/ CERTIFICATE #

50887

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

Location Address

417 Te Moana Road Waikanae

Customer Details:

Name: Michael & Melissa Meads

Address: 417 Te Moana Road

Phone: 0272210730

Name of Electrical worker:

Matt Meadlem

Registration/Practising licence number:

E 260636

Company Details:

BRIEN ELECTRICAL LTD 15 IHAKARA ST, PARAPARAUMU 04 298 7053 info@brienelectrical.co.nz

Type of work:

- ☐ Additions
☐ Alterations
☒ New work

The prescribed electrical work is:

- ☐ Low risk
☒ General
☐ High risk (Specify):

Specify type of supply system:

- ☒ 240V MEN
☐ 400V MEN

Reference Standards:

- ☐ Part 1 of AS/NZS 3000
☒ Part 2 of AS/NZS 3000
☐ Additional Standards:

Description of work:

Install new meterboard switchboard with new mcbs and rcd protection

Date/range of dates that prescribed electrical work undertaken:

I certify that the completed prescribed electrical work to which this certificate applies has been done lawfully and safely, and the information in the certificate is correct in that the installation, or part of the installation:

- ☐ Has been installed in accordance with the specified certified design¹
☒ Has an earthing system that is correctly rated (where applicable)
☒ Contains fittings that are safe to connect to a power supply
☐ Relies on a supplier Declaration of Conformity¹
☐ Relies on a manufacturer's instructions¹
☒ Has been tested in accordance with the Electricity (Safety) Regulations 2010
☒ Is safe to connect

¹ Attach or reference. If it is impractical to attach a copy of a manufacturer's instructions, or of any certified design or supplier declaration of conformity, provide a reference to where the documents can be found, in a readily accessible format, by electronic means.

Test Results

Polarity (Independent Earth):	
Insulation Resistance:	99.9 MΩ
Earth Continuity:	Ω
Bonding:	Ω
Fault Loop impedance:	.4 Ω
Other (specify): PSSC	Ka

Certifier's signature:

Date:

01/03/2022

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name:

Matt Meadlem

Registration/Practising licence number:

E 260636

Certifier's signature:

Certificate Issue Date:

01/03/2022

CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS
This certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.



www.brienelectrical.co.nz

15 Ihakara Street
PO Box 790
Paraparaumu
info@brienelectrical.co.nz

Tel. 04-2987053 04-4710459
Kapiti Wellington
GST # 32-061-508

PLEASE PAY BY	AMOUNT	INVOICE DATE
07/03/2022	\$2738.05	28/02/2022

TAX INVOICE NO. 49707

Michael & Melissa Meads
417 Te Moana Road
Waikanae
Wellington 5036

Job No.: 50887
Site: 417 Te Moana Road Waikanae
Site Contact:
Phone: 0272210730
Order No.:

Description

ELECTRICAL OPTIONS, AS QUOTED.

Pricing adjusted due to switchboard not moving position
Works to gate box extra to quoted works.
Electrician to return to fit power outlet and tidy switchboard.

Rel

9/3/22

THANK YOU FOR YOUR CUSTOM. PAYMENT DUE WITHIN 7 DAYS PLEASE.

Receipt of this invoice is acknowledgement of our Terms & Conditions which can be viewed on our website. All materials remain the property of Brien Electrical Ltd until paid in full. Claimed under the Construction Contracts Act 2002. Overdue accounts will incur interest at 2.5% per month compounding plus all debt collection fees.

Sub-Total ex GST	\$2380.90
GST	\$357.15
Total inc GST	\$2738.05
Amount Applied	\$0.00
Balance Due	\$2738.05

How To Pay



Direct Credit

Bank ANZ
Acc. Name Brien Electrical Ltd
Acc. No. 06-0730-0073690-00



Credit Card (MasterCard or Visa - 2.5% surcharge applies)

INVOICE NO. 49707

Please Reference: 49707

DUE DATE: 07/03/2022 AMOUNT DUE: \$2738.05

