Clutha District Council

PO Box 25 Balclutha Phone 03 419 0200
Fax 03 418 3185

Building Consent No BLD/2012/14411

Section 51, Building Act 2004
Issued in accordance with Project Information Memorandum No BLD/2012/14411

The Building

Street Address:
49 LEWIN STREET , BALCLUTHA

Legal Description:
LOT 1 DP 12639

Building Name:

Location Within Site/Block:

Level/Unit No (if applicable):

Valuation Roll No: 28703/303/00

The Owner

Name/s:
ALAN MARTIN and
SHIRLEY CONSTANCE MARTIN

Contact Person:

Mailing Address:
49 LEWIN STREET
BALCLUTHA 9230

Street Address:

Daytime Ph: 03 412 8608
A/hrs Ph:
Mobile:
Fax: **Email:**

Building Work

The following building work is authorised by this building consent:

INSTALL SOLID FUEL HEATER - EVOLUTION PELLET FIRE

In accordance with the plans and specifications submitted with the building consent application.

Value of Work $6,000.00

First Point of Contact

First Point of Contact for Communications with Clutha District Council:

Name:
EDWARDS PLUMBING & HEATING LIMITED

Mailing Address:
PO BOX 82
BALCLUTHA 9240

Phone Numbers:
Home:
Work: 418 3308

This building consent is issued under section 51 of the Building Act 2004. This building consent does not relieve the owner of the building (or proposed building) of any duty or responsibility under any other Act relating to or affecting the building (or proposed building).

This building consent also does not permit the construction, alteration, demolition, or removal of the building (or proposed building) if that construction, alteration, demolition, or removal would be in breach of any other Act.

GASFITTING CERTIFICATE OF COMPLIANCE – GAS SAFETY CERTIFICATE

Certificate of Compliance:

Client Name: A & SC Martin

Reference / Job #: | **ICP (if known):**

Address of work: 49 Lewis St

Suburb: Balclutha **Town / City:**

Description of gasfitting work: (If different gasfitting work was done by different people, state who did what gasfitting.)

Move gas Bottle to outside as per code Purge & test 8.25 kpa all ok

Gas supply pressure 3.1 kPa **Risk classification** (tick one) ☑ Low-Risk ☐ General ☐ High-risk

Gas type (tick one) ☐ Natural gas ☑ LPG ☐ Biogas ☐ Other (specify)

The work has been done in accordance with a certified design: ☐ Yes ☑ No

If yes – identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link:

The work relies on manufacturer's instructions: ☑ No ☐ Yes:

If yes – identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate.
(Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link:

The work has been done in accordance with means of compliance (specify):

☑ Yes – AS/NZS 5601.1 sections 3 to 6 ☐ Yes – AS/NZS 5601.2 sections 3 to 9 ☐ No

Were any other standards or gas code of practice required for compliance?

☐ Yes (specify) ☑ No

Parts of the gas installation to which this certificate relates that are safe to connect to a gas supply?

☑ All ☐ Parts (specify)

Date(s) on which the work was done: 27/3/19

Name and registration number of anyone who carried out work under supervision:

By signing this document I confirm that I am satisfied that the work described in this certificate of compliance has been done lawfully and safely, and that the information on this certificate is correct.

Certifier name: Colin Smith **Registration number:** 25245

Certifier Signature: **Date:** 27/3/19

Gas Safety Certificate:

By signing this document I confirm that the work described in this Gas Safety Certificate, and the installation or part installation, is connected to a gas supply and is safe to use.

Name of person authorised to certify the connection: Colin Smith

Registration number: 25245 **Date of completion or connection** 27/3/19

Certifier Signature: **Date:** 27/3/19

This Gas Safety Certificate confirms that the gasfitting work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.

Healthy Homes Inspection Report



Client	Don McKenzie c/- Harcourts Highland Real Estate Group Ltd
Property Address	49 Lewin Street , Balclutha, Clutha, 9230
Date of Report	15/02/2021
Inspection ID	70691

0800 422 386
info@bettagroup.co.nz
www.bettapropertycompliance.co.nz
© Betta NZ Ltd 2021 All rights reserved.

INSPECTION DETAILS

Kieran Thornton on behalf of KT Inspections Ltd trading as Betta Property Compliance
Office: PO Box 11157, Hastings, 4158
Free Phone: 0800 422 388
info@bettagroup.co.nz

Monday, 15th February 2021
Don McKenzie c/- Harcourts Highland Real Estate Group Ltd
RE: HEALTHY HOMES INSPECTION

Report requested by:	Property Manager
Inspection date:	15/02/2021
Reference number:	70691
Property address:	49 Lewin Street , Balclutha, Clutha, 9230
Tenants details:	The tenants were home at the time of the inspection
Inspector:	Kieran Thornton

Purpose
The purpose of the Healthy Homes report is to establish whether the property complies with the Residential Tenancies (Healthy Homes Standards) Regulations 2019. The inspection report will document what is required to either confirm the PCBU is compliant with the current Healthy Homes regulations or provide enough information for the PCBU to understand what is required to make the property comply.

NOTE: the inspector is completely independent and is acting impartially at all times.

Methodology
The inspector will systematically work their way around the interior and exterior of the property documenting the six key standards of a Healthy Home (Heating, Insulation, Ventilation, Moisture, Drainage, Draught Stopping) .

Limitations
- Every care has been taken in carrying out this inspection to communicate an accurate record of the property's current level of compliance with the Residential Tenancies (Healthy Homes Standards) Regulations 2019.
- The inspection is a record of what was inspected on the day of the inspection. Compliance aspects of the house can change from time to time.
- Furniture, fixtures and fittings or any chattels in the property including the tenant's personal possessions will not be moved during the course of the inspection. This can make it difficult and at times impossible to make comment on areas of the property. If this is the case, this will be noted in the report.
- The report is based on a VISUAL inspection only.
- This report is not a structural, electrical, building, asbestos or methamphetamine report, nor does it focus specifically on any other aspects of the property other than the six standards that make a healthy home (for the avoidance of doubt these are Heating, Insulation, Ventilation, Moisture, Drainage, Draught Stopping).
- The statements contained in this report are prepared solely for the purposes of determining the health of a building. It is not to be interpreted or utilized in any other manner whatsoever (including but not limited to soundness of the structure or defects)
- The report is prepared for the client to whom this report is addressed and no liability will be accepted for any third party, incorrect use or omission.
- This report is to be read in conjunction with the Betta Property Compliance terms of trade.

Other
Photographs of the property were taken at the time of the inspection unless the client expressly requested otherwise.
Areas that could not be accessed do not form part of this report.
If you have any questions regarding the scope of the inspection, please do not hesitate to call 0800 422 386 to discuss.
Thank you for choosing Betta Property Compliance to undertake your Healthy Homes inspection report.
Kind Regards
Kieran Thornton on behalf of KT Inspections Ltd trading as Betta Property Compliance

© Betta NZ Ltd 2021 All rights reserved.

INSPECTION RESULTS INTERPRETATION

Within the report data sheets, the below color rating has been attributed to each of the Healthy Home elements.

Compliance of an element

Color Rating	Rating	Definition
	Complies	The inspector has determined that the Healthy Homes element complies (bymeeting the minimum required standard) with the Residential Tenancies (HealthyHomes Standards) Regulations 2019.
	Does **NOT** comply	The inspector has determined that the healthy homes element does not meet the minimum required standard of the Residential Tenancies (Healthy Homes Standards) Regulations 2019. Work is required to meet compliance.

Minimum Insulation Requirements

INSULATION MINIMUM VALUES			
Zone 1 and 2		**Zone 3**	
Ceiling	R2.9	Ceiling	R3.3
Underfloor	R1.3	Underfloor	R1.3



Definitions (as per the Residential Tenancies (Healthy Homes Standards) Regulations 2019).

Bathroom:
means a domestic living space in which a bath or shower is installed.

Domestic Living Space
means an interior space of a building that is a space for activities normally associated with domestic living.

Extractor Fan
means an extractor fan that vents extracted air to the outdoors.

Habitable Space
means a domestic living space excluding any bathroom, laundry, toilet, pantry, walk-in wardrobe, corridor, hallway, lobby, clothes-drying room, or other space of a specialised nature occupied neither frequently nor for extended periods.

Kitchen
means a domestic living space in which an indoor cooktop is installed.

Living Room
means a room that consists of, or includes, a habitable space that is for use, or could reasonably be expected to be used for general everyday living, whether as a lounge room, dining room, sitting room, family room, or other similar use.

Room
room means an area within residential premises that
(a) consists of, or includes, 1 or more habitable spaces; and
(b) is or can be fully enclosed by the floor, the ceiling, floor-to-ceiling walls, and closeable windows and doors.

Meaning of not reasonably practicable to install
It is not reasonably practicable to install something at any premises or tenancy building if, because of the way the premises or tenancy building is designed or built,
(a) a professional installer cannot access the relevant area of the premises or tenancy building to install the thing without
  (i) carrying out substantial building work; or
  (ii) causing substantial damage to the premises or tenancy building; or
(b) a professional installer cannot install the thing without creating greater risks to the health or safety of any person than are normally acceptable when something of that kind is being installed by a professional installer; or
(c) it is otherwise not reasonably practicable for a professional installer to install the thing.

© Betta NZ Ltd 2021 All rights reserved.

SUMMARY

Below is a summary of the ratings for each compliance component.

HEATING *Refer to page 5* G	INSULATION *Refer to page 8* G
VENTILATION *Refer to page 11* G	DRAUGHTS *Refer to page 17* G
DRAINAGE & GUTTERING *Refer to page 18* G	MOISTURE BARRIER *Refer to page 21* G

© Betta NZ Ltd 2021 All rights reserved.

HEATING

This section covers the heat source. Only the heat source in the main living area is assessed in this report. The functionality of the heat source was not inspected or commented on, nor was its efficiency. This report only comments on its compliance with the Residential Tenancies (Healthy Homes Standards) Regulations 2019. No heat sources where operated or tested as part of this inspection.

Where any technical knowledge or any specific tools or skills are required, the landlord is generally required to maintain the heating device including cleaning any filters. This comes under their obligation to keep the heater source in good working order. Eg. A flued gas heater must have its fixtures and fittings in good working order to ensure there is not gas leak. Additionally a wood burner must have its flue and chimney in good working order to ensure it is safe to operate. The inspector is unable to ascertain this information from the inspection and this is not reported on within this report.

In order to meet Healthy Homes compliance, gas heaters must be†flued.† Approved gas heaters should have a compliance†label on the side stating kW or BTU output. †If there is no label, then the landlord or property manager is required to check compliance / engage the services of a gas filter / heating specialist & ascertain safety.

Wood and pellet burners require a building consent for installation or modification and must meet council requirements, plus any National Environmental Standards for Air Quality.† This has been unable to be confirmed by the inspector, therefore this has not been commented on in this report.

Required heating capacity (calculations on Appendix One) are calculated using a custom-built calculator not the online calculator provided for the public. Results may vary slightly from online calculators.

Restrictions: **None.**

Heat source type: **Heat pump.**



Heat source type: **Solid fuel burner (fire)**



© Betta NZ Ltd 2021 All rights reserved.

Heat source make: **Mitsubishi.**



Heat source make:




Heat source rating/capacity: **6.2kW**



© Betta NZ Ltd 2021 All rights reserved.

Heat source rating/capacity:	**10.0kW.**



Required heating capacity (calculations on Appendix One):	**8.72kW**
Is the heat source positioned to heat the main living room:	**Yes.**
Does the heat source have thermostat:	**Yes.**
Heat source condition:	**Good.**
Compliance:	
Additional comments:	**As per the calculator, the Heating required for the living area is 8.72kW. The current heat source provides 10kW, therefore the heating complies with the Healthy Homes Standards.**

Heating requirements as documented in the (as per the Residential Tenancies (Healthy Homes Standards) Regulations 2019)

8(1) The main living room of the premises must be heated by 1 or more qualifying heaters with a total heating capacity of at least the required heating capacity for the main living room.

9(1) A heater is a qualifying heater if
(a) it is installed as a fixture to the premises; and
(b) either
(i) the heater (or if it is a fixed heat pump, the indoor unit) is in the living room; or
(ii) the heater supplies heat directly into the living room (for example, through a duct or
(c) it has a heating capacity of at least 1.5 kW; and
(d) if it is an electric heater or a fixed heat pump, it has a thermostat; and
(e) it is not an unacceptable heater.
(2) Each of the following is an unacceptable heater:
(a) an open fire:
(b) an unflued combustion heater:
(c) if the required heating capacity for the living room is greater than 2.4 kW, an electric heater.
(3) In this regulation,
electric heater means an electric heater that is not a fixed heat pump
fixed heat pump means a heat pump that is permanently wired into the premises' electrical system.

© Betta NZ Ltd 2021 All rights reserved.

INSULATION


This section covers the roof and underfloor spaces. Due to Health & Safety requirements the subfloor and roof space is only inspected from the manholes, and therefore those areas which could not be viewed from the manholes could not be commented on.

Ceiling


Restrictions: **The roof space inspection was limited. We could not complete a full inspection of the roof space, Our visual inspection was made from the inspection hatch. Only areas visible from the inspection hatch were observed and comments included in this report.**

Insulation type: **Polyester.**

What is the thickness of the insulation: **200mm**



Estimated R-value: **R3.2.**



Insulation condition: **Good Condition.**

Compliance:

Additional comments: **The ceiling insulation complies due to the insulation exceeding the minimum R2.9 / 3.3 rating required for this climate zone.**

© Betta NZ Ltd 2021 All rights reserved.


Underfloor

Restrictions: **None.**

Insulation type: **Polyester.**



What is the thickness of the insulation?: **115mm**



Estimated R-value: **R1.8.**



Insulation condition: **Good Condition.**

© Betta NZ Ltd 2021 All rights reserved.

Compliance:

Additional comments: **The underfloor insulation complies due to the insulation exceeding the minimum R1.3 rating required.**

General

Wall insulation details: **Unknown**

Installation date for ceiling: **Unknown**

Installation date for underfloor: **Unknown**

Installation date for walls: **Unknown**

Insulation requirements as documented in the (as per the Residential Tenancies (Healthy Homes Standards) Regulations 2019).

14 Qualifying ceiling insulation
(1) Ceiling insulation is qualifying ceiling insulation if all of the following apply:
(a) the insulation's R-value, when it was installed, was,
(i) if the premises are in zone 1 or zone 2, at least 2.9; or
(ii) if the premises are in zone 3, at least 3.3:
(b) the insulation was installed in accordance with NZS 4246:2016: **(located on page 3 of this report)**
(c) the insulation is in a reasonable condition (or better).
(2) If the ceiling insulation for an area of ceiling consists of 2 or more products installed on top of each other, the insulation's R-value for the purposes of subclause (1)(a) is to be determined by
(a) determining the R-value of each product when it was installed; and
(b) adding those R-values together

16 Qualifying underfloor insulation
(1) Underfloor insulation is qualifying underfloor insulation if all of the following apply:
(a) the insulation's R-value, when it was installed, was at least 1.3:
(b) the insulation was installed in accordance with NZS 4246:2016: **(located on page 3 of this report)**
(c) the insulation is in a reasonable condition (or better).
(2) If the underfloor insulation for an area of floor consists of 2 or more products installed on top of each other, the insulation's R-value for the purposes of subclause (1)(a) is to be determined by
(a) determining the R-value of each product when it was installed; and
(b) adding those R-values together

18 Determining whether insulation is in reasonable condition
(1) In determining whether insulation is in reasonable condition (or better), the following matters must be taken into account:
(2) Without limiting subclause (1), ceiling insulation is not in reasonable condition if the minimum thickness of the insulation material is less than 120 mm.
(3) However, subclause (2) does not apply if the landlord proves that
(a) the insulation's R-value, when it was installed, was the value specified in regulation 14(1)(a)(i) or (ii) (as applicable); and
(b) the current thickness of the insulation material is 70% or more of its thickness when it was installed (even if its current thickness is less than 120 mm).

In addition
Ceiling insulation installed before 1 July 2016 is exempt from R-Values provided the minimum thickness of the insulation material is at least 120 mm. If records show it was installed post 2016, then it will need to be topped up to meet the R2.9 / R3.3 requirement for this climate zone.

© Betta NZ Ltd 2021 All rights reserved.

VENTILATION

This section covers the ventilation of each habitable space. This report only comments on its compliance with the Residential Tenancies (Healthy Homes Standards) Regulations 2019. No mechanical ventilation was tested as part of this inspection.

Ventilation

Restrictions: **None.**

Kitchen/s

Mechanical Ventilation Type: **Rangehood.**



Mechanical Ventilation Condition: **Good.**

Is the size of the Mechanical Ventilation adequate: **Yes.**

Are all Mechanical Vents ventilating to the exterior: **Yes.**




Compliance:

© Betta NZ Ltd 2021 All rights reserved.


Additional comments:	**Kitchen Extractor Complies with Healthy Homes standards, which state that 'kitchen extractor fans installed before 1st July 2019 have no minimum size or performance requirements but fans must be in good working order and ventilate to outdoors'. This extractor appears to comply with these requirements, however if Property Manager/Landlord is aware that the installation took place after 1/7/19 then the ducting will need to comply with the minimum of 150 mm.**

Bathroom/s

Mechanical Ventilation Type:	**Mechanical Extractor unit.**



Mechanical Ventilation Condition:	**Good.**
Is the size of the Mechanical Ventilation adequate:	**Yes.**
Are all Mechanical Vents ventilating to the exterior:	**Yes.**



Compliance:	
Additional comments:	**Bathroom Extractor Complies with Healthy Homes standards, which state that 'bathroom extractor fans installed before 1st July 2019 have no minimum size or performance requirements but fans must be in good working order and ventilate to outdoors'. This extractor appears to comply with these requirements, however if Property Manager/Landlord is aware that the installation took place after 1/7/19 then the ducting will need to comply with the minimum of 120 mm.**

© Betta NZ Ltd 2021 All rights reserved.

Ensuite

Mechanical Ventilation Type:

Mechanical Ventilation Condition:

Is the size of the Mechanical Ventilation adequate:

Are all Mechanical Vents ventilating to the exterior:

Compliance:


Additional comments: **N/A**

Windows

Does the area of the window meet the minimum 5% requirement of floor space in each room: **Yes.**

Is there one opening window or door in each habitable room: **Yes.**

Are all exterior opening windows and doors able to be fixed in position: **Yes. Bathroom**




Are all exterior opening windows and doors able to be fixed in position: **Yes. Toilet**



© Betta NZ Ltd 2021 All rights reserved.

Are all exterior opening windows and doors able to be fixed in position: **Yes. Lounge**



Are all exterior opening windows and doors able to be fixed in position: **Yes. Kitchen**



Are all exterior opening windows and doors able to be fixed in position: **Yes. Dining**



© Betta NZ Ltd 2021 All rights reserved.

Are all exterior opening windows and doors able to be fixed in position:	**Yes. Bedroom 1**



Are all exterior opening windows and doors able to be fixed in position:	**Yes. Bedroom 2**



Are all exterior opening windows and doors able to be fixed in position:	**Yes. Bedroom 3**



Compliance:	
Additional comments:	**The window ventilation section of the Healthy Homes Standards is fully compliant.**

© Betta NZ Ltd 2021 All rights reserved.

Ventilation requirements as documented in the (as per the Residential Tenancies (Healthy Homes Standards) Regulations 2019).

21 Openable windows or external doors
(1) Each habitable space in the premises must have 1 or more qualifying windows or doors.
(2) The total openable area of the qualifying windows or doors in the habitable space must be at least 5% of the floor area of the habitable space.
(3) A window, skylight, or door is a qualifying window or door if it
(a) opens to the outdoors; and
(b) is designed and built in a way that allows it to remain fixed in the open position during normal occupation of the premises
(4) The openable area of a qualifying window or door is its net openable area on the internal face of the building element in which it is located.

23 Extractor fans for kitchens and bathrooms
(1) Each kitchen and bathroom in the premises must have an extractor fan installed in it.
(2) For a kitchen,
(a) the fan and all exhaust ducting must have a diameter of at least 150 mm; or
(b) the fan and all exhaust ducting must have an exhaust capacity of at least 50 /s.
(3) For a bathroom,
(a) the fan and all exhaust ducting must have a diameter of at least 120 mm; or
(b) the fan and all exhaust ducting must have an exhaust capacity of at least 25 /s.

In addition (as per tenancy services release Aug 2019) :
Extractor fans installed BEFORE 1 July 2019: No minimum size or performance requirements but fans must be in good working order and ventilate to outdoors. This means that the range hood or extractor fan must not vent back into the kitchen or bathroom, into a roof space or other space. Any ducting must be connected, intact (i.e. without tears or holes) and installed so that extracted air can flow freely through it (e.g. no unnecessary kinks or compressions). Any grills or filters must be unclogged.

© Betta NZ Ltd 2021 All rights reserved.

DRAUGHTS

This section covers the draughts between the interior and exterior of the building. Draughts can vary in severity depending on building movement, and may be affected by thermal expansion. Only major draughts consisting of a gap of over 3mm will be commented on.

Draughts

Restrictions:	**None.**
Are there any open fires located in the dwelling that are not adequately sealed:	**No.**
Are there any gaps or cracks larger than 3mm which may cause draughts:	**No.**
Compliance:	
Additional comments:	**This home is fully compliant with all aspects of the draughts section of the Healthy Homes Standards.**

Draught Stopping requirements as documented in the (as per the Residential Tenancies (Healthy Homes Standards) Regulations 2019).

25 Open fireplaces to be blocked

(1) If the premises have an open fireplace, it must be closed off, or its chimney must be blocked, in a way that prevents draughts into and out of the premises through the fireplace.

(2) However, subclause (1) does not apply if

(a) the tenant requests in writing that the fireplace be available for use; and

(b) the landlord agrees to the request

(3) If subclause (1) is disapplied under subclause (2), the fireplace and its chimney must be

(a) free from gaps or holes that allow draughts into or out of the premises and that are not necessary for the safe and efficient operation of the fireplace; and

(b) maintained in good working order.

26 Gaps and holes that allow draughts

(1) The premises must be free from gaps between, and holes in, building elements that

(a) are not intentional parts of the construction of the premises (such as drainage and ventilation openings); and

(b) allow draughts into or out of the premises; and

(c) are unreasonable.

(2) In determining whether a gap or hole is unreasonable for the purposes of subclause (1)(c), the following matters may be taken into account:

(a) the size and location of the gap or hole:

(b) the extent of the draught that is allowed through the gap or hole:

(c) if there is more than 1 gap or hole at the premises, the extent of the total draught that is allowed through those gaps and holes:

(d) the likely impact that a draught through the gap or hole will have on heat loss from the premises:

(e) any other relevant matters, subject to subclause (3).

(3) In determining whether a gap or hole is unreasonable for the purposes of subclause (1)(c), the age and condition of the premises or tenancy building must not be taken into account.

© Betta NZ Ltd 2021 All rights reserved.

DRAINAGE & GUTTERING

This section covers site drainage and roof water management. It does not comment on the weathertightness of the property or any water ingress. The report only comments on its compliance with the Residential Tenancies (Healthy Homes Standards) Regulations 2019. Due to the nature of some sites inspection may be limited for both the site drainage and guttering systems due to factors such as planting, elevation and site contour. The efficiency of the drainage or guttering systems where not tested. The systems were visually inspected only.

Restrictions:	**Roof was inspected from the ladder, access to the roof was not gained.**
Is there any evidence of stormwater pooling/ponding around the site:	**No.**
Do all the roof areas have gutters & downpipes catching the roof water:	**Yes.**



Do all the roof areas have gutters & downpipes catching the roof water:	**Yes.**



© Betta NZ Ltd 2021 All rights reserved.

Do all the roof areas have gutters & downpipes catching the roof water:

Yes.



Do all the roof areas have gutters & downpipes catching the roof water:

Yes.



Gutter & Downpipe condition:

Good.




© Betta NZ Ltd 2021 All rights reserved.

Gutter & Downpipe condition:	**Good.**



Do the downpipes discharge into a stormwater reticulation system:	**Yes.**



Do the downpipes discharge into a stormwater reticulation system:	
Compliance:	
Additional comments:	**Drainage & Guttering Complies with Healthy Homes Standards at the time of inspection.**

Drainage System requirements as documented in the (as per the Residential Tenancies (Healthy Homes Standards) Regulations 2019).

27 Tenancy building to have efficient drainage system
(1) The tenancy building must have a drainage system that efficiently drains storm water, surface water, and ground water to an appropriate outfall.
(2) The drainage system must include appropriate gutters, downpipes, and drains for the removal of water from the roof.

© Betta NZ Ltd 2021 All rights reserved.

MOISTURE BARRIER

This section covers the moisture barrier in the subfloor. It does not comment on the weathertightness of the property or any water ingress. The report only comments on its compliance with the Residential Tenancies (Healthy Homes Standards) Regulations 2019. Due to Health & Safety requirements the subfloor is only inspected from the manhole, and therefore those areas which could not be viewed from the manholes could not be commented on.

Restrictions: **An area moisture barrier was not able to be inspected, Therefore we were unable to report on any defects which may have been present in this area. Due to access restrictions, some photos and comments were made based on visual inspection from some distance.**

Is the subfloor enclosed: **Yes.**

Is there an adequately installed ground vapour barrier: **Yes.**



Is the subfloor ventilated: **Yes.**



Compliance:

Additional comments: **The moisture barrier complies with Healthy Homes Standards at the time of inspection.**

© Betta NZ Ltd 2021 All rights reserved.

Drainage System requirements as documented in the (as per the Residential Tenancies (Healthy Homes Standards) Regulations 2019).

28 Suspended floors to have ground moisture barrier

(1) This regulation applies if

(a) the tenancy building has a suspended floor; and

(b) the subfloor space is enclosed.

(2) The tenancy building's subfloor space must

(a) have a ground moisture barrier that

(i) is made of a material that meets the specifications for an onground vapour barrier set out in section 8 of NZS 4246:2016; and

(ii) was installed in accordance with section 8 of NZS 4246:2016; or

(b) have an alternative ground moisture barrier that

(i) has a vapour flow resistance of at least 50 MN s/g; and

(ii) was installed by an appropriate professional installer.

3) A subfloor space is enclosed if the airflow into and out of the space is significantly obstructed along at least 50% of the perimeter of the subfloor space by 1 or more of the following:

(a) a masonry foundation wall:

(b) cement boards, timber skirting, or other cladding:

(c) other parts of the building or any adjoining structure:

(d) any other permanent or semi-permanent structure that significantly obstructs airflow:

(e) rock, soil, or other similar material.

© Betta NZ Ltd 2021 All rights reserved.

HEATING CALCULATIONS - APPENDIX ONE

The required heating capacity for a living room is to be calculated using the following formula:

$$h = [t + v + (f \times 40)] / 1000$$

Where-

- h is the required heating capacity for the living room (kW)
- t is the transmission heat loss of the living room (W)
- v is the ventilation heat loss of the living room (W)
- f is the area of the floor of the living room (m2)

Calculations:

h = 8.72 = [5017.15 + 583.22 + (77.97 * 40)] / 1000

© Betta NZ Ltd 2021 All rights reserved.

SUMMARY OF COMPLIANCE - APPENDIX TWO

Below is a summary of the ratings for each compliance component.

HEATING	
G	As per the calculator, the Heating required for the living area is 8.72kW. The current heat source provides 10kW, therefore the heating complies with the Healthy Homes Standards.
INSULATION	
G	The ceiling insulation complies due to the insulation exceeding the minimum R2.9 / 3.3 rating required for this climate zone. The underfloor insulation complies due to the insulation exceeding the minimum R1.3 rating required.
VENTILATION	
G	Kitchen Extractor Complies with Healthy Homes standards, which state that 'kitchen extractor fans installed before 1st July 2019 have no minimum size or performance requirements but fans must be in good working order and ventilate to outdoors'. This extractor appears to comply with these requirements, however if Property Manager/Landlord is aware that the installation took place after 1/7/19 then the ducting will need to comply with the minimum of 150 mm. Bathroom Extractor Complies with Healthy Homes standards, which state that 'bathroom extractor fans installed before 1st July 2019 have no minimum size or performance requirements but fans must be in good working order and ventilate to outdoors'. This extractor appears to comply with these requirements, however if Property Manager/Landlord is aware that the installation took place after 1/7/19 then the ducting will need to comply with the minimum of 120 mm. N/A The window ventilation section of the Healthy Homes Standards is fully compliant.
DRAUGHTS	
G	This home is fully compliant with all aspects of the draughts section of the Healthy Homes Standards.
DRAINAGE & GUTTERING	
G	Drainage & Guttering Complies with Healthy Homes Standards at the time of inspection.
MOISTURE BARRIER	
G	The moisture barrier complies with Healthy Homes Standards at the time of inspection.

© Betta NZ Ltd 2021 All rights reserved.

HEALTHY HOMES INSPECTION CERTIFICATE

Report Identification Number: 70691

Property Address: 49 Lewin Street , Balclutha, Clutha, 9230

Client Name: Don McKenzie c/- Harcourts Highland Real Estate Group Ltd

This certifies that the above property has been inspected and meets the compliance requirements of the Residential Tenancies (Healthy Homes Standards) Regulations 2019

Issue Date: 15/02/2021

Expiry Date: 15/02/2024

Signed by the Inspector:
Kieran Thornton

BALCLUTHA BOROUGH COUNCIL

House Connection Plan

APPLICATION No.

DATE


SCALE $\frac{1}{8}$ in. to a foot

NEW SEWERAGE DRAINS: RED

STORMWATER: DOTTED BLACK

OLD DRAINS: FULL BLACK

49



Owner B.D. STEVESON Block

Street LEWIN Section

Locality Rosebank Allotment

Signature of Drainer M D Smith