

**HOWARD CAMPBELL AND SONS LTD.**

P.O. BOX 30, LYN, ON K0E 1M0

PHONE / FAX 613-342-6105

*add Septic Inspection*

DATE *8/21/21* TIME *8:45*

**A. GENERAL INFORMATION**

Property Owner(s): ~~XXXXXXXXXX~~ Representing Owner(s): \_\_\_\_\_

Mailing Address: \_\_\_\_\_ Postal Code: \_\_\_\_\_

Inspection Location: 3022 Nationalview Drive

Tel #: \_\_\_\_\_ Alternative Tel #: \_\_\_\_\_ Fax #: \_\_\_\_\_

Municipality: \_\_\_\_\_

Cottage Seasonal:  Yes  No Residential:  Yes  No Commercial:  Yes  No Other: \_\_\_\_\_

**B. INSPECTION DETAILS**

Septic Tank:  Yes  No Tank Type:  Concrete  Fiber  Poly  Steel  Other \_\_\_\_\_ Size of Tank: *300gal*

Pump Out:  Yes  No Frequency:  Annual  2-3  3-4  4-5  >5  Never

Inlet Baffle:  Good  Poor  Missing Outlet Baffle:  Good  Poor  Missing Number of Compartments: 2

Comments: System looks to be in good working condition on the date of inspection

Tile Bed:  Yes  No Bed Type:  Raised  Inground  Trench  Filter  Area Other: \_\_\_\_\_

Bed Conditions:  Wet  Lush Veg  Trees  Exposed Pipe  Erosion  Slopes Comments: Ran water into bed for 30min with good flow. No run back.

Grey Water Disposal Type: \_\_\_\_\_ Comments: \_\_\_\_\_

Holding Tank:  Yes  No Tank Type:  Concrete  Fiber  Poly  Steel  Other \_\_\_\_\_ Size of Tank: \_\_\_\_\_

All Grey Water Directed to Holding Tank:  Yes  No

Warning Device:  Yes  No Alarm Working:  Yes  No Pump Out Agreement:  Yes  No Pumper: \_\_\_\_\_

Comments: \_\_\_\_\_

**However, we are in no position to guarantee the continuing operation of the septic system or holding tank**

3057

Inspected By: Dave Campbell

Invoice Number: 41178